

**PLACER COUNTY
AIR POLLUTION CONTROL DISTRICT**

NOTICE OF PUBLIC HEARING

**PROPOSED AMENDED RULE 247, NATURAL GAS-FIRED WATER
HEATERS, SMALL BOILERS, AND PROCESS HEATERS**

Placer County Air Pollution Control District proposes to adopt amended Rule 247 which limits the sale and installation of new natural gas-fired water heaters, small boilers and process heaters in the range of 75,000 Btu/hr to 5 million Btu/hr to emissions of no more than 20 ppmv of NOx. This emission limit is effective on January 1, 2015. The amendment is to alter the marking requirements on the units.

On Thursday, February 13, 2014, at their regular meeting beginning at 2:30 PM, the Placer County Air Pollution Control District Board of Directors will hold a public hearing to receive comments and consider the adoption of the amended rule. The hearing is to be held at the Placer County Board of Supervisors Chambers, 175 Fulweiler Avenue, Auburn, California.

All interested parties are advised of the opportunity to comment on the proposed rules. The proposed rules and their support documents can be viewed at the District's website at www.placer.ca.gov/apcd. Written comments should be addressed to Mr. John Finnell at the District office, located at 110 Maple Street, Auburn, CA 95603. The District phone number is (530) 745-2330.